

Type of Charging Station(s)

### **Development Services Department** 77 Fair Dr.

Costa Mesa, CA 92626

#### **Building Division**

T: (714) 754-5273 Mon-Thurs & alternating Fridays 8:00 a.m. to 5:00 p.m. buildinginfo@costamesaca.gov

Check one

## Eligibility Checklist for Expedited Electric Vehicle Charging Station Permit:

# Multi-Family Dwellings Power Levels (proposed circuit rating)

Level 1	110/120 volt alternating current (VAC) at 15 or 20 Amps	L	
Level 2 - 3.3 kilowatt (kW) (low)	208/240 VAC at 20 or 30 Amps		
Level 2 – 6.6kW (medium)	208/240 VAC at 40 Amps		
Level 2 – 9.6kW (high)	208/240 VAC at 50 Amps		
Level 2 – 19.2kW (highest)	208/240 VAC at 100 Amps		
Other (provide	Provide rating:	Г	
detail):			
Permit Application Requirem			
A. Does the application include E	VCS manufacturer's specs and installation guidelines?	Y	N
Electrical Load Calculation W			
A. Is an electrical load calculatio	n worksheet included? (CEC 220)	☐ Y	$\square$ N
B. Based on the load calculation worksheet, is a new electrical service panel upgrade required?			□N
1) If yes, do plans include the electrical service panel upgrade?			□N
C. Is the charging circuit appropriately sized for a continuous load of 125%?			
	ed is a Level $2-9.6\mathrm{kW}$ station with a circuit rating of 50 ed circuit card with electrical calculations included with	ΠY	□N
Site Plan and Single Line Draw	wina:		
Site Plan and Single Line Drav  A Is a site plan and separate 6	<del>_</del>		
A. Is a site plan and separate e     with the permit application	electrical plan with a single-line diagram included ?	☐ Y	□N
A. Is a site plan and separate e with the permit application     1) If mechanical ventilation	electrical plan with a single-line diagram included	□ Y	□ N
A. Is a site plan and separate exists with the permit application     1) If mechanical ventilation requirements (CEC 625.	electrical plan with a single-line diagram included ? n requirements are triggered for indoor venting 52 (B)), is a mechanical plan included with the		
A. Is a site plan and separate enter with the permit application  1) If mechanical ventilation requirements (CEC 625. permit application?	electrical plan with a single-line diagram included? n requirements are triggered for indoor venting 52 (B)), is a mechanical plan included with the ened and drawn to scale?		□ ×
A. Is a site plan and separate entire with the permit application  1) If mechanical ventilation requirements (CEC 625. permit application?  B. Is the site plan fully dimension 1) Showing location, size, a	electrical plan with a single-line diagram included? n requirements are triggered for indoor venting 52 (B)), is a mechanical plan included with the ened and drawn to scale?	□ Y	

Α. [	es the plan include EVCS manufacturer's specs and installation guidelines?	ΠΥ				
В. [	es the electrical plan identify the amperage and location of existing electrical					
	ervice panel?  If yes, does the existing panel schedule show room for additional breakers?					
	he charging unit rated more than 60 amps or more than 150V to ground?	<u> </u>				
C. I	If yes, are disconnecting means provided in a readily accessible location in line of					
	site and within 50' of EVCS. (CEC 625.43)	∐ Y	<u></u>			
	es the charging equipment have a Nationally Recognized Testing Laboratory IRTL) approved listing mark? (UL 2202/UL 2200)	Υ	1			
E. I1	enching is required, is the trenching detail called out?	Y	1			
	Is the trenching in compliance with minimum cover requirements for wiring methods or circuits? (18" for direct burial per <b>CEC 300.5</b> )	□ Y	1			
	the CAL Green EV Readiness installation requirements apply to this project:	☐ Y				
	Do the plans demonstrate conformance with mandatory measures for 10% of total parking spaces, for new multifamily dwellings provided for all types of parking facilities, to be electric vehicle charging spaces (EV spaces) capable of supporting future EVCS? (4.106.4.2)	□ Y	<u> </u>			
	Do the construction documents indicate the location of the proposed EV spaces where at least one is located in common use areas and available to all residents for use? (4.106.4.2.2, Item 3) Calculations for the required number of EV spaces shall be rounded up to the nearest whole number.	Y				
	When EV chargers are installed, EV spaces required by Section 4.106.4.2.2, Item 3 shall comply with at least one of the following options:  a. The EV space shall be located adjacent to an accessible parking space that complies with CBC Chapter 11A, to allow use of the EV charger from the accessible parking space.  b. The EV space shall be located on an accessible route, as defined by CBC Chapter 2, to the building.  c. EV charging space(s) comply with Section 4.106.4.2.2.1.2, Items 1, 2 and 3.	Y	1			
	This criteria is intended for an expedited EVCS permitting process. If any items are checked NO, please revise plans to fit within the eligibility checklist; otherwise the permit application may go throug the standard plan review and approval process. Plan review commences the day after submittal with up to 3 business days for qualifying expedited projects and up to 10 business days for all other EVCS projects.					
	ectrical plans shall be completed, stamped and signed by a California Licensed Electri C-10 electrical contractor.	icai Eng	gineer			
	CS project review is limited to health and safety requirements found under local, state w. EVCS permit approval is not subject to approval of an association (as defined in Second Code).					
ect	ldress:					
	Signature:					
dica	Jighalore.					
lico						



### **Development Services Department** 77 Fair Dr.

Costa Mesa, CA 92626

### **Building Division**

T: (714) 754-5273 Mon-Thurs & alternating Fridays 8:00 a.m. to 5:00 p.m. buildinginfo@costamesaca.gov

## Eligibility Checklist for Expedited Electric Vehicle Charging Station Permit: Non-Residential Buildings and Facilities

pe of Charging Station(s)	Power Levels (proposed circuit rating)	Chec	K Or
Level 1	110/120 volt alternating current (VAC) at 15 or 20 Amps	3 [	
Level 2 - 3.3 kilowatt (kW) (low)	208/240 VAC at 20 or 30 Amps		
Level 2 – 6.6kW (medium)	208/240 VAC at 40 Amps	[	
Level 2 – 9.6kW (high)	208/240 VAC at 50 Amps	[	
Level 2 – 19.2kW (highest)	208/240 VAC at 100 Amps	[	
Other (provide detail):	Provide rating:		
rmit Application Requirement.  Does the application include E	VCS manufacturer's specs and installation guidelines?	Y	
ectrical Load Calculation W  Is an electrical load calculation	orksheet:  n worksheet included? (CEC 220)	ΠY	T
. Based on the load calculation required?	worksheet, is a new electrical service panel upgrade	Y	
	the electrical service panel upgrade?	Υ	
. Is the charging circuit appropri	ately sized for a continuous load of 125%?	Y	
	ed is a Level 2 – 9.6 kW station with a circuit rating of 50 d circuit card with electrical calculations included with	ПΥ	
Amps or higher, is a complete the single line diagram?	a circuit cara wiiri elecifical calculations included wiiri		
the single line diagram?  The Plan and Single Line Drav	ving: electrical plan with a single-line diagram included	Y	
the single line diagram?  e Plan and Single Line Drav  Is a site plan and separate e with the permit application  1) If mechanical ventilation	ving: electrical plan with a single-line diagram included		
the single line diagram?  Pe Plan and Single Line Draw  Is a site plan and separate e with the permit application  1) If mechanical ventilation requirements (CEC 625.9)	ving: electrical plan with a single-line diagram included requirements are triggered for indoor venting (B)), is a mechanical plan included with the	Y	
the single line diagram?  e Plan and Single Line Drav  Is a site plan and separate e with the permit application  1) If mechanical ventilation requirements (CEC 625.9 permit application?	ving: electrical plan with a single-line diagram included electrical plan with a single-line diagram included electrical plan included electrical plan included with the med and drawn to scale?	Y Y	
Is a site plan and separate e with the permit application requirements (CEC 625.5 permit application?  Is the site plan fully dimension of the site plan fully dimens	ving: electrical plan with a single-line diagram included electrical plan with a single-line diagram included electrical plan included electrical plan included with the med and drawn to scale?	Y Y	

Compliance with the California Electrical Code:									
A. Does the plan include EVCS manufacturer's specs and installation guidelines?	ПΥ	ПИ							
B. Does the electrical plan identify the amperage and location of existing electrical service panel?	Y								
1) If yes, does the existing panel schedule show room for additional breakers?	ΠY	ПИ							
C. Is the charging unit rated more than 60 amps or more than 150V to ground?	Y	z							
<ol> <li>If yes, are disconnecting means provided in a readily accessible location in line of site and within 50' of EVCS. (CEC 625.43)</li> </ol>	Υ	Z							
D. Does the charging equipment have a Nationally Recognized Testing Laboratory (NRTL) approved listing mark? (UL 2202/UL 2200)	Δ	N							
E. If trenching is required, is the trenching detail called out?	ΠY	N							
<ol> <li>Is the trenching in compliance with minimum cover requirements for wiring Methods or circuits ?(18" for direct burial per CEC 300.5)</li> </ol>	Υ	Z							
Compliance with the California Green Building Standards Code (CGBSC):  A. Do the CAL Green EV Readiness installation requirements apply to this project?	□Y	□N							
	ш								
Do the plans demonstrate conformance with <b>CGBSC Table 5.106.5.3.1</b> for the minimum required number of charging spaces?	Υ	ПИ							
2) Do the construction plans comply with the design requirements set forth in CGBSC 5.106.5.3.1 for EV Capable Spaces and CGBSC 5.106.5.3.2 for Electric Vehicle Charging Station?	ΠY	ПИ							
B. Do the plans clearly depict all required accessible EVCS features for the disabled?	lures:	□N							
Do the plans identify the correct number and type of accessible EVCS stalls required in accordance with Table 11B-228.3.2.1?	ΠY	Z							
2) Do the plans detail compliance with the accessible EVCS features required by 11B-812 and Figure 11B-812.9?	ΠY	ПИ							
Notes: This criteria is intended for an expedited EVCS permitting process. If any items are checked NO, please revise plans to fit within the eligibility checklist; otherwise the permit application may go through the standard plan review and approval process. Plan review commences the day after submittal vup to 3 business days for qualifying expedited projects and up to 10 business days for all other EVCS projects.									
Electrical plans shall be completed, stamped and signed by a California Licensed Electrical Engineer or a C-10 electrical contractor.									
EVCS project review is limited to health and safety requirements found under local, state law. EVCS permit approval is not subject to approval of an association (as defined in Se the Civil Code).									
Project Address:									
Applicant Signature:									
Applicants Printed Name:									
Contractor's License Number and type:									